

Mounting Instruction

Product Parameters

	<ol style="list-style-type: none"> 1. Model: 5009 2. Pole Lten:T-00H1-H 3. Rated Voltage: AC 120-240V 4. Rated Power: LED <input type="checkbox"/>36W <input type="checkbox"/>48W <input type="checkbox"/>60W 5. IP Grade: IP65 6. Insulation protection level: Class I 7. Operating Temperature: -30~+45°C
--	--

Components and Tools

	<p>Flange</p>	<p>Mounting holes</p>
--	---------------	-----------------------

Installation Steps

<p>A</p> <p>Recessed Box</p> <p>OFF</p> <p>▲ The depth of foundation pit shall be determined by digging to the original soil. In case of backfill, the recessed box can be embedded only after water injection and settlement.</p> <p>▲ After the recessed box are embedded for 72H (3 days), shall the lamp be mounted only when the concrete is completely solidified.</p>	<p>B</p>	<p>C</p> <p>OFF</p> <p>▲ Wiring must be operated in accordance with construction specifications.</p>	
<p>D</p> <p>▲ Please be sure to fasten tightly of the flange.</p>	<p>E</p> <p>ON</p> <p>▲ Connect the power supply, and light up the lamp.</p>	<p>F</p>	<p>G</p>

Attention

1. Lamp should be installed by professional electrician;
2. The light source contained in this luminaire shall only be replaced by the manufacturer or his service agent or a similar qualified person;
3. Check the power switch has been turned off;
4. Please read this user guide carefully before installation and keep for future reference;
5. If the external flexible cable or cord of this luminaire is damaged, it shall be exclusively replaced by the manufacturer or his service agent or a similar qualified person in order to avoid a hazard.